



DJ Micky NE Entertainments
 3 Bakers Gardens
 Dunston
 NE11 9HA

CMD Pat Testing
 9 Middlefield
 Pelton
 DH2 1DP

Test Date : 30/07/2024

Tel : 07861 688 388
 info@cmdpattesting.co.uk

PAT Serial Number : E007031
 Tested By : CD

APP ID	Description	Location	Class	Visual	Earth (Ω)	Insulation	Leakage (mA)	Result	Notes
17070	IEC LEAD	MOBILE	I	Pass	0.09	>20.00		Pass	
17071	IEC LEAD	MOBILE	I	Pass	0.07	>20.00		Pass	
17072	IEC LEAD	MOBILE	I	Pass	0.12	>20.00		Pass	
17073	IEC LEAD	MOBILE	I	Pass	0.05	>20.00		Pass	
17074	IEC LEAD	MOBILE	I	Pass	0.06	>20.00		Pass	
17075	IEC LEAD	MOBILE	I	Pass	0.07	>20.00		Pass	
17076	IEC LEAD	MOBILE	I	Pass	0.09	>20.00		Pass	
17077	EXT 5 WAY	MOBILE	I	Pass	0.05	>20.00		Pass	
17078	EXT 3 WAY	MOBILE	I	Pass	0.05	>20.00		Pass	
17079	EXT 3 WAY	MOBILE	I	Pass	0.06	>20.00		Pass	
17080	EXT 4 WAY	MOBILE	I	Pass	0.07	>20.00		Pass	
17081	CLOVERLEAF	MOBILE	I	Pass	0.01	>20.00		Pass	
17082	POWER SUPPLY	MOBILE	II	Pass				Pass	
17083	CLOVERLEAF	MOBILE	I	Pass	0.05	>20.00		Pass	
17084	SPEAKER	MOBILE	I	Pass	0.05	>20.00	0.04	Pass	
17085	SPEAKER	MOBILE	I	Pass	0.07	>20.00	0.31	Pass	
17086	DJ LIGHT	MOBILE	I	Pass	0.09	>20.00	1.06	Pass	
17087	MIXER	MOBILE	I	Pass	0.09	>20.00	0.04	Pass	
17088	DJ LIGHT	MOBILE	I	Pass	0.05	>20.00	0.71	Pass	
17089	DJ LIGHT	MOBILE	I	Pass	0.08	>20.00	1.07	Pass	

17090	SPEAKER	MOBILE	I	Pass	0.06	>20.00	0.04	Pass
-------	---------	--------	---	------	------	--------	------	------